



FSP-1043
FIRE STOP PILLOW
(ORANGE BAG)



FSP-1312
FIRE STOP PUTTY
(WRAPPED IN PAPER)



THROUGH-PENETRATION PRODUCTS FOR USE IN
THROUGH-PENETRATION FIRESTOP SYSTEMS. SEE UL FIRE
RESISTANCE DIRECTOR. 23XP



CLASSIFIED BY UNDERWRITERS LABORATORIES, INC.
AS TO ITS SUITABILITY AS AN EQUIPMENT
GROUNDING CONDUCTOR ONLY. 556E

UL CROSS SECTIONAL AREA				
	TRAY HEIGHT			
WIDTH	4	5	6	7
6	1.00	1.00	1.00	1.50
9	1.00	1.00	1.50	1.50
12-42	1.50	1.50	1.50	1.50

"CT" TYPE TRAY INCLUDES 2 PAIR 9ZN-800*
SPICE PLATES WITH 3/8" ZINC PLATED HARDWARE
"D" TYPE TRAY INCLUDES 2 PC OF CAC-UFB SPLICE
WITH ZINC PLATED HARDWARE.
"U" TYPE TRAY DOES NOT INCLUDE SPLICE HARDWARE.
EXAMPLE USES INCLUDE WIRE BASKET OR HALF-RACK.

P=PREGALVANIZED

FWS = FIRE
WALL SLEEVE

9P-FWS-CT-4-12

TRAY TYPE
CT = CABLE TRAY
D = DATA-TRACK
U = UNIVERSAL

TRAY HEIGHT
4
5
6
7

TRAY WIDTH
(INCHES)
6
9
12
18
24
30
36
42

EACH CATALOG NUMBER INCLUDES:
WALL SLEEVE
NELSON FIRE STOP PILLOWS
NELSON FIRE STOP PUTTY
SPLICE PLATES (2 SETS)

EATON

509 WEST MONROE STREET
HIGHLAND, ILLINOIS 62249
PHONE (618)-654-2184

TITLE: FIRE WALL
SLEEVE KIT

EQUIPMENT FURNISHED HAS BEEN FABRICATED
IN ACCORDANCE WITH THIS DRAWING.

PRODUCT DWG. NO'S:

SHEET OF

DRAWN BY: BMT

DRAWING NO. S13011

DATE: 2/19/04