


CLASSIFIED BY UNDERWRITERS LABORATORIES, INC.  
AS TO ITS SUITABILITY AS AN EQUIPMENT  
GROUNDING CONDUCTOR ONLY. 556E

"CT" TYPE TRAY INCLUDES 2 PAIR 9ZN-800\*  
SPLICE PLATES WITH 3/8" ZINC PLATED HARDWARE  
"D" TYPE TRAY INCLUDES 2 PC OF CAC-UFB SPLICE  
WITH ZINC PLATED HARDWARE.  
"U" TYPE TRAY DOES NOT INCLUDE SPLICE HARDWARE.  
EXAMPLE USES INCLUDE WIRE BASKET OR HALF-RACK.

WIDTH	UL CROSS SECTIONAL AREA			
	TRAY HEIGHT			
4	5	6	7	
6	1.00	1.00	1.00	1.50
9	1.00	1.00	1.50	1.50
12-36	1.50	1.50	1.50	1.50



**EATON**

509 WEST MONROE STREET  
HIGHLAND, ILLINOIS 62249  
PHONE (618)-654-2184

TITLE:

WALL SLEEVE KIT

EQUIPMENT FURNISHED HAS BEEN FABRICATED  
IN ACCORDANCE WITH THIS DRAWING.

PRODUCT DWG. NO'S:

SHEET OF

DRAWN BY: BMT

DRAWING NO. S13012

DATE: 2/19/04